

PAT CERTIFICATE

This certificate confirms that all electrical equipment as indicated
on the Pat Register of

THE DISCO CO DH1 5PW

Has successfully passed PAT TESTING

CERT NO 306052

EXPIRES JUNE 2026



07759 326300

TESTED & AUTHORISED BY S.TERRY

Pat Testing has been carried out in accordance with the
**IET Code of Practice for In-Service Inspection and Testing of
Electrical Equipment(5ed 2020)**
and in compliance with Health & Safety No34c(February 2015)
and HSG107(3ed 2013)

By a qualified Engineer, using calibrated Test Equipment





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	I EA Touch Leak m/A~	Diff Leak m/A~				
1	R C D UNIT	I	√	√	√	√	0.03	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
2	IEC LEAD	II	√	√	√	√	-	> 19.99	<0.10	-	√	JUNE 2025	JUNE2026	ON SITE
3	240V EXT LEAD	I	√	√	√	√	0.20	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
4	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
5	IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
6	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
7	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	0.16	√	JUNE 2025	JUNE2026	ON SITE
8	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	0.17	√	JUNE 2025	JUNE2026	ON SITE
9	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
10	IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
11	DESK LAMP	II	√	√	√	√	-	> 19.99	<0.10	-	√	JUNE 2025	JUNE2026	ON SITE
12	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
13	240V EXT LEAD	I	√	√	√	√	0.27	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
14	240V EXT LEAD	I	√	√	√	√	0.18	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
15	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE

PAT REGISTER





The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
16	GIG BAR 3	I	✓	✓	✓	✓	0.12	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
17	IEC LEAD	I	✓	✓	✓	✓	0.05	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
18	IEC LEAD	I	✓	✓	✓	✓	0.11	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
19	IEC LEAD	I	✓	✓	✓	✓	0.07	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
20	BUBBLE UNIT	I	✓	✓	✓	✓	0.1	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
21	IEC LEAD	I	✓	✓	✓	✓	0.07	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
22	IEC LEAD	I	✓	✓	✓	✓	0.09	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
23	240VEXT LEAD	I	✓	✓	✓	✓	0.23	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
24	IEC LEAD	I	✓	✓	✓	✓	0.07	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
25	240V EXT LEAD	I	✓	✓	✓	✓	0.25	> 19.99	-	0.16	✓	JUNE 2025	JUNE2026	ON SITE
26	240V EXT LEAD	I	✓	✓	✓	✓	0.22	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
27	IEC LEAD	I	✓	✓	✓	✓	0.07	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
28	WF SPEAKER	I	✓	✓	✓	✓	0.13	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
29	8 WAY IEC LEAD	I	✓	✓	✓	✓	0.10	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE
30	240V EXT LEAD	I	✓	✓	✓	✓	0.20	> 19.99	-	< 0.15	✓	JUNE 2025	JUNE2026	ON SITE



PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
31	240V EXT REEL	I	√	√	√	√	0.37	> 19.99	-	0.18	√	JUNE 2024	JUNE2025	ON SITE
32	240V EXT LEAD	I	√	√	√	√	0.26	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
33	240V EXT LEAD	I	√	√	√	√	0.23	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
34	IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
35	WF SPEAKER	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
36	WF SPEAKER	I	√	√	√	√	0.14	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
37	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
38	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
39	DESK FAN	II	√	√	√	√		> 19.99	<0.10	-	√	JUNE 2025	JUNE2026	ON SITE
40	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
41	CHAUVE LED	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
42	IEC LEAD	I	√	√	√	√	0.04	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
43	CHAUVE LED	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
44	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	0.16	√	JUNE 2025	JUNE2026	ON SITE
45	240V EXT REEL	I	√	√	√	√	0.31	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
46	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
47	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
48	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
49	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
50	240V EXT REEL	I	√	√	√	√	0.31	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
51	PD8E UNIT	I	√	√	√	√	0.05	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
52	240V EXT LEAD	I	√	√	√	√	0.21	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
53	240V EXT LEAD	I	√	√	√	√	0.18	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
54	240V EXT LEAD	I	√	√	√	√	0.25	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
55	IEC LEAD	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
94	IEC LEAD	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
57	IEC TO 240V SOCKET	I	√	√	√	√	0.11	> 19.99	-	0.16	√	JUNE 2025	JUNE2026	ON SITE
58	W/AUDIO ACTIVE SPEAKER	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
59	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
60	IEC LEAD	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
61	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
62	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
63	IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
64	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
65	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
66	IEC LEAD	I	√	√	√	√	0.04	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
67	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
68	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
69	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
70	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
71	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
72	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
73	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
74	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
75	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
76	IEC LEAD	I	√	√	√	√	0.05	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
77	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
78	IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
79	IEC SOCKET	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
80	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
81	IEC LEAD	I	√	√	√	√	0.05	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
82	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
83	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
84	IEC TO 240V EXT SCT	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
85	IEC TO 240V EXT SCT	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
89	DESK LAMP	II	√	√	√	√	-	> 19.99	0.10	-	√	JUNE 2025	JUNE2026	ON SITE
90	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	TRAILER
91	LAP TOP CHARGER	II	√	√	√	√	-	> 19.99	0.10	-	√	JUNE 2025	JUNE2026	ON SITE
92	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
93	LAP TOP CHARGER	II	√	√	√	√	-	> 19.99	0.10	-	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	I EA Touch Leak m/A~	Diff Leak m/A~				
91	240V EXT LEAD	I	√	√	√	√	0.22	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	VAN
92	IEC SOCKET	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
93	240V EXT LEAD	I	√	√	√	√	0.18	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
94	240V EXT LEAD	I	√	√	√	√	0.19	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
95	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
96	IEC SOCKET	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
97	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
98	IEC SOCKET	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
99	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
100	IEC SOCKET	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
101	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
102	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
103	8 WAY IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
104	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
105	8 WAY IEC UNIT	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	I EA Touch Leak m/A~	Diff Leak m/A~				
106	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
107	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
108	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
109	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
110	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
111	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
112	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
113	IEC SOCKET	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
114	IEC LEAD	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
115	IEC SOCKET	I	√	√	√	√	0.11	> 19.99	-	0.16	√	JUNE 2025	JUNE2026	ON SITE
116	240V EXT LEAD	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
117	TRICLOPS	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
118	IEC SOCKET	I	√	√	√	√	0.10	> 19.99	-	0.18	√	JUNE 2025	JUNE2026	ON SITE
119	IEC SOCKET	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
120	IEC SOCKET	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	I EA Touch Leak m/A~	Diff Leak m/A~				
136	240V EXT LEAD	I	√	√	√	√	0.21	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
137	8 WAY IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
138	240V EXT LEAD	I	√	√	√	√	0.26	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
139	IEC LEAD	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
140														
141														
142														
143														
144														
145														
146	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
147														
148														
149	DYNAMO 250	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
150														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
151														
152	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
153	240V EXT LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
154	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
155	W/A SPEAKER	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
156	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
157	8 WAY IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
158														
159														
160														
161	IEC LEAD	I	√	√	√	√	0.14	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
162														
163	IEC LEAD	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
164	SKYTRONIC SPKR	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
165														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
166	W/A SPEAKER	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	ON SITE
167	SKY TEC SPKR	I	√	√	√	√	0.14	> 19.99	-	0.16	√	JUNE 2025	JUNE2026	ON SITE
168	CD PLAYER	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	ON SITE
169	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
170														
171														
172														
173														
174	DYNAMO 250	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
175														
176														
177														
178														
179														
180	240V EXT LEAD	I	√	√	√	√	0.19	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	VAN





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
181														
182	TRICLOPS	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
183														
184														
185														
186														
187														
188														
189														
190														
191	DYNAMO 250	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
192														
193	IEC LEAD	I	√	√	√	√	0.17	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
194														
195														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
196	IEC SOCKET	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
197	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
198														
199														
200														
201	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
202	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	0.17	√	JUNE 2025	JUNE2026	ON SITE
203														
204														
205														
206														
207														
208														
209														
210	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
211	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
212														
214	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	0.16	√	JUNE 2025	JUNE2026	ON SITE
215														
216														
217	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	0.16	√	JUNE 2025	JUNE2026	ON SITE
218														
219														
220														
221														
222														
223														
224														
225	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
226														
227														
228	TRICLOPS	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
229														
230														
231														
232														
233	SKYTEC SPKR	I	√	√	√	√	0.14	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
234														
235														
236	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
237														
238	DYNAMO	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
239														
240														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
241	TRICOPS	I	√	√	√	√	0.12	> 19.99	-	0.18	√	JUNE 2025	JUNE2026	ON SITE
242	IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
243														
244														
245	QTX LIGHT	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
248	DYNAMO 250	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
249														
250														
251	QTX LIGHT	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
252														
253														
254														
255														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
256	IEC LEAD	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
257														
258	IEC LEAD	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
259	DYNAMO 250	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
260														
261														
262	W/S SPEAKER	I	√	√	√	√	0.14	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
263														
264														
265														
266	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
267														
268	IEC LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
269	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
270														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
271														
272														
273														
274														
275														
276														
277														
278														
279														
280														
281														
282														
283														
284														
285														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
286														
287														
288														
289														
290														
291														
292														
293														
294														
295														
296														
297														
298														
299														
300														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

Equip No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
301														
302														
303														
304														
305														
306														
307														
308														
309														
310														
311														
312														
313														
314														
315	240V EXT LEAD	I	√	√	√	√	0.08	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

[illegible]



PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

EQUIP No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
331	DYNAMO 250	I	√	√	√	√	MIRROR 0.09	CRACKED > 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
332														
333														
334														
335														
336														
337														
338														
339														
340	DYNAMO 250	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
341														
342														
343	DYNAMO 250	I	√	√	√	√	0.16	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	TRAILER
344														
345														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
346														
347														
348	240V EXT LEAD	I	√	√	√	√	0.28	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
349														
350	240V EXT LEAD	I	√	√	√	√	0.19	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
351														
352	DYNAMO 250	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
353	DYNAMO 250	I	√	√	√	√	0.11	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
354														
355														
356														
357	DENON	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	ON SITE
358														
359														
360	NEWMARK CD PLAYER	II	√	√	√	√	-	> 19.99	-	-	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
361														
362														
363	DYNAMO 250	I	√	√	√	√	0.12	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
364	240V EXT LEAD	I	√	√	√	√	0.21	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
365	240V EXT LEAD	I	√	√	√	√	0.17	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
366	240V EXT LEAD	I	√	√	√	√	0.18	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
367														
368														
369														
370														
371														
372														
373														
374														
375	NEWMARK C D	II	√	√	√	√	-	> 19.99	-	-	√	JUNE 2025	JUNE2026	ON SITE





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
376														
377														
378														
379														
380														
381														
382														
383	IEC LEAD	I	√	√	√	√	0.13	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
384	DENON D J PSU	I	√	√	√	√	0.10	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
385														
386														
387														
388														
389														
390														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	I EA Touch Leak m/A~	Diff Leak m/A~				
391														
392	2040V EXT LEAD	I	√	√	√	√	0.23	> 19.99		< 0.15	√	JUNE 2025	JUNE2026	ON SITE
393														
394	MIXER	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	ON SITE
395														
396	CLASS 2 LEAD	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	HOUSE
397	LAP TOP CHARGER	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	HOUSE
398	IEC LEAD	I	√	√	√	√	0.16	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
399	LAP TOPCHARGER	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	HOUSE
400	CLASS 2 LEAD	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	HOUSE
401	CHARGER	II	√	√	√	√	-	> 19.99	< 0.10	-	√	JUNE 2025	JUNE2026	ON SITE
402	240V ADAPTOR	I	√	√	√	√	0.16	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
403														
404														





PAT REGISTER

The Disco Co - 70 Canterbury Rd Durham DH1 5PY

No	Equipment Description	Formal Visual Inspection					Test				OK To use	Date of Test	Date of Retest	Location
		Class	Flex	Body	Plug	Fuse	P/Earth Continuity Ω	@ 500V Insulation M Ω	IEA Touch Leak m/A~	Diff Leak m/A~				
128	240VEXT LEAD	I	√	√	√	√	0.20	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
129	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
130	IEC LEAD	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
131	240VEXT LEAD	I	√	√	√	√	0.18	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
132	IEC SOCKET	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
133	IEC SOCKET	I	√	√	√	√	0.06	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
134	IEC LEAD	I	√	√	√	√	0.09	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE
135	IEC LEAD	I	√	√	√	√	0.07	> 19.99	-	< 0.15	√	JUNE 2025	JUNE2026	ON SITE

